



### Building Inspection Cure Sheet

Project: **Vintage at the Crossings**

Pass ☐ Fail ☒

Building(s) Inspection		
Physical Findings	Cure Period	Date Corrected
1. Two 3" by 3" holes in ceiling taped up (outside unit 415).	60 days	
2. First floor staircase door knob not operable (right wing of building).	30 days	
3. Expired fire extinguisher (outside gym).	30 days	
4. Expired fire extinguisher (outside trashroom #1).	30 days	
5. Carpet threshold ripped off wall (near unit 150 and 151).	60 days	
6. Improperly disposed and excessive litter near outdoor dumpster bin.	30 days	
7. Ventilator grate clogged in trash room #1.	30 days	
8. Trash room #1 first trash bin is full; recommend swapping to avoid excessive trash buildup. (Recommendation)		

