



**THIS PLAN IS INTENDED FOR
PRELIMINARY REVIEW ONLY
NOT FOR CONSTRUCTION**



NOXIOUS WEEDS NOTE

FIRE FLOW ANALYSIS
FIRE FLOW REQUIREMENT IS 4,750 GALLONS PER MINUTE
@ 20 PSI RESIDUAL PRESSURE FOR 4 HOURS.
BASED ON THE LARGEST ONSITE BUILDING:
SQUARE FOOTAGE 51,000 S.F.
LARGEST AREA BETWEEN 4-HOUR AREA SEPARATION

BUILDING HEIGHT: 18'
NUMBER OF STORES: 1 FLOOR
TYPE OF CONSTRUCTION: II-B
OCCUPANCY GROUP: S-1
PULL AUTOMATIC FIRE SPRINKLER
RENEWED BY: BIRMINGHAM FIRE DEPARTMENT

[illegible]